

BOARD OF DIRECTORS  
Orville Downer  
Randy Franke  
Ken Morin  
Wayne Miller  
Bernie Otjen  
  
CHIEF OF DISTRICT  
J. Kevin Henson



FOUR CORNERS STATION  
MIDDLE GROVE STATION  
PRATUM STATION  
MACLEAY STATION  
BROOKS STATION  
CLEAR LAKE STATION  
LABISH CENTER STATION  
COLLEGE STATION

## Bon Fire Permit Requirements

A bon fire is considered a woodpile larger than 2 feet in height and larger than 3 feet in diameter. Requirements for a bon fire are as followed:

1. If request is made during dry summer months, and District is in “No-Burn” status, no permit will be issued.
2. Kindle and maintain fire at the approved location only. This permit is not transferable to another location.
3. The fire shall be burning during the date and time period indicated on the permit.
4. Locate the fire a minimum of 50 feet from any structure. Additionally, prior to ignition, eliminate conditions that could cause fire to spread to within 50 feet of any structure.
5. Fire extinguishing equipment shall include a minimum of 20 gallons of water or a charged hose, (two) fire extinguishers rated a minimum of 3-A:40-B:C, and two shovels within 25’ of the fire
6. This permit **does not** authorize the burning of domestic rubbish, refuse or combustible waste such as paper, cartons, rags, lumber, oils, plastics, foliage, stubble, composition roofing or siding, rubber or other objectionable materials.
7. Wood is the only fuel allowed. This includes starting the fire.
8. The person who starts the fire is required to be an adult who is familiar with the requirements of this permit. A small, approved torch may be used.
9. The maximum dimensions of the woodpile shall be 6’ in height and all other dimensions shall not exceed 10’.
10. The adult supervisor signing the permit agrees to be responsible for all aspects of the fire and safety of the participants. An adult supervisor shall have a working cell phone at all times during the fire to summon 911 help for fire or medical.
11. Noise or smoke complaints from neighbors, wind conditions or any other reason may lead to the **immediate** revocation of the permit and extinguishments of the fire.